

APPLIANCE WIRING MATERIAL

Subj.758 Section 3 Page 3662 Issued:2001-03-05

Revised:2012-12-11

Style 3662 Single conductor with extruded insulation

Rating 180 deg C, 4200 Vac, Horizontal flame.

Conductor 1.5 to 400 sq. mm, solid or stranded.

Insulation Extruded SR.

Conductor size	<u>Minimum average</u>	Minimum thickness at any
	thickness	<u>point</u>
1.5-95.0 sq mm	70 mils	65 mils
95.1-240.0 sq mm	100 mils	90 mils
240.1-400.0 sq	120 mils	108 mils

Covering Optional, non-metallic.

Standard Appliance Wiring Material UL 758.

Marking General.

Use Internal wiring.

UL and the UL Logo are trademarks of UL LLC $\ \odot$ 2018

Consigliato da:



